

Message

From: Floyd. Megan [FloydM@saccounty.net]
Sent: 8/1/2017 2:23:16 PM
To: Garcia-Bakarich, Luis [Garcia-Bakarich.Luis@epa.gov]
Subject: RE: Sacramento County ALEs

Good morning Luis,

Here are updates for the Lead ALE

CA3400149 Rancho Marina- 90th percentile for the second compliance period was ND. They are taking another round of samples for this 6 month compliance period to determine if they are actually exceeding the action level.

CA3400229 Rio Cosumnes Correctional Center- 90th percentile samples for the second compliance period indicated that they did exceed the action level for lead. Samples were taken to protocol but at sites that were not representative for the Lead & Copper rule. The water system owner has been provided an estimate for consolidation to a larger public utility. Water system took multiple samples at locations in 15 second intervals to determine if they could isolate the potential problem. They have taken their samples for this compliance period to determine where the potential issue may be.

CA3400332 Oxbow Marina- connected to California American Water Isleton on July 18, 2017. This system is no longer regulated by the LPA. The SWRCB engineer that oversees this system is aware of the lead action level exceedance.

CA3400335 Holiday Mobile Village- 90th percentile for the second compliance period was ND. 90th percentile for this compliance period was 11.2 ppb however, they did not resample the original locations that exceeded. They are going to resample the two locations that put them over the action level exceedance no later than September 30, 2017 and the 90th percentile will be recalculated. If the samples are less than the action limit they will go back to annual monitoring.

If you have any questions please feel free to contact me. Thank you

Megan Floyd, R.E.H.S
Environmental Specialist
Sacramento County Environmental Management Department
10590 Armstrong Ave, Mather CA 95655
(916) 876-7888
(916) 875-8513 Fax

From: Garcia-Bakarich, Luis [mailto:Garcia-Bakarich.Luis@epa.gov]
Sent: Monday, July 31, 2017 9:57 AM
To: Floyd. Megan
Cc: Rezvani, Ali@Waterboards; Killou, Wendy@Waterboards
Subject: Sacramento County ALEs

Megan,

Can you please provide me with an update on the systems below which all appear to have active lead and copper action level exceedances from 2016.

CA3400149 RANCHO MARINA

